



NOTES:

1. FIRE HYDRANT SHALL HAVE A MAXIMUM BURY OF 7'-0". MODIFICATION OF THE HYDRANT LEAD TO MEET THIS REQUIREMENT SHALL BE IN THAT SECTION FROM THE VALVE TO THE HYDRANT AS PER STANDARD DETAIL L-7601.
2. FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
3. TEE USED TO CONNECT THE HYDRANT LEAD TO WATER MAIN IS INCLUDED IN COST OF ITEM 809, FIRE HYDRANT.

CONCRETE BACKING AGAINST UNDISTURBED EARTH PER STD. DWG. L-6311

<p>CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER</p>	<p>STANDARD DETAIL TYPICAL TYPE "A" MODIFIED HYDRANT SETTING (DOUBLE VALVE SET UP IN CURB)</p>	<div style="border: 1px solid black; border-radius: 50%; width: 60px; height: 60px; margin: 0 auto; display: flex; align-items: center; justify-content: center;"> L-6637C </div>
<p>APPROVED: ADMINISTRATOR </p>	<p>5-16-13 DATE</p>	